

CERTIFICATE: ATEX / SVTI / ISO



aquasant[®]

Electro optical overfilling, "Filling and
leakage" for petro products





CERTIFICATE

Certificate no. 6972

aquasant 

Aquasant Messtechnik AG
Hauptstrasse 22
CH-4416 Bubendorf

QS ZÜRICH AG certifies that the management system of the above mentioned company and location(s) has been evaluated and meets the requirements established by the following rules:

ISO 9001: 2015

The management system includes:

Development, manufacturing and sales of measuring-, monitoring- and controlling-equipment for the chemical industry, the biotechnology, the food industry and the petrochemistry

During the period of validity of this certificate, the management system of the company must always comply with the requirements of the certified standards.

For updated amendments within the scope of certification of the present certificate, please refer to

<http://www.quality-service.ch/>



First certification date:

01.03.1996

Date of issue:

25.05.2021

Expiration date:

01.07.2024

Subject to successful surveillance audit

QS ZÜRICH AG

P.O. Box 6335

CH-8050 Zürich

info@quality-service.ch




Management



CERTIFICATE

- 1 **Production Quality Assurance Notification**
- 2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU
- 3 Notification Number: **KIWA 19ATEXQ1234 Issue: 1**
- 4 This Notification is issued for the equipment, protective systems and components which are described in the EU-Type Examination Certificates listed in the schedule of this Notification.
- 5 Manufacturer: **Aquasant Messtechnik AG**
Address: **Hauptstrasse 22, 4416 Bubendorf
Switzerland**
- 6 Production site: **Aquasant Messtechnik AG**
Address: **Hauptstrasse 22, 4416 Bubendorf
Switzerland**
- 7 Kiwa Nederland B.V., notified body number 0063 in accordance with Article 17 of the Council Directive 2014/34/EU of 26 February 2014, notifies to the manufacturer that the production site satisfies the requirements of Annex IV and VII of the Directive.
- 8 This Notification is based on Audit Report No. 191001279 and is valid until 24 October 2022. Periodical surveillance of the production process is part of this notification. This Notification can be withdrawn if the manufacturer no longer satisfies the requirements of Annex IV and VII.
- 9 According to Article 16 (3) of Directive 2014/34/EU the CE marking shall be accompanied by the identification number 0063 of Kiwa Nederland B.V. as notified body involved in the production control stage.
According to Article 13 (3) components shall not be provided with the CE marking.

Kiwa Nederland B.V.
Unit Kiwa ExVision
Wilmersdorf 50
P.O. Box 137
7300 AC Apeldoorn
The Netherlands

Tel. +31 88 998 34 93
Fax +31 88 998 36 85
ExVision@kiwa.nl
www.kiwaexvision.com

Kiwa Nederland B.V.

Ronald Karel
Managing Director

Issue date:

6 November 2019

First issue:

© Integral publication of this notification in its entirety and without any change is allowed.

EU-DECLARATION OF CONFORMITY



Manufacturer: Aquasant Messtechnik AG, Hauptstrasse 22, 4416 Bubendorf, Switzerland

Brand: aquasant®

Notified body: N° 2813, CSA Group Testing UK Ltd

Description: Electrooptical rod liquid sensor for overfill protection with electronics within the sensor sleeve for connection to AS*-/AN*-Aquasant control units, according to ATEX 16 type code.

We hereby declare under our sole responsibility that the products:

Product: Liquid sensor (Special fill safety leaks)
Model: **AF21* / AF23* / AF26* / AF33* / AF42***
EU-Type Examination Certificate Number: SEV 16 ATEX 0151 X Electrosuisse SEV Nr.: 1258

comply with the following European guidelines under the harmonised standards or normative documents:

ATEX RL 2014/34/EU	EN 60079-0:2012+A11:2013 EN 60079-11:2012 EN 60079-26:2015 EN 60079-28:2015
EMV RL 2014/30/EU	EN 61000 EN 61326
RoHS RL 2011/65/EU	EN IEC 63000:2018
SVTI Special fill safety leaks SM 312836	KVU 301.001 KVU 302.004
Water protection suitability according to KVU	KVU 321.003

Bubendorf, 15.03.2021



Roger Inauen
Head Manufacturing





(1) **EU-Type Examination Certificate**

(2) Equipment or protective system intended for use in potentially explosive atmospheres - **Directive 2014/34/EU**

(3) Certificate number: **SEV 16 ATEX 0151 X**

(4) Product: Liquid detector Type AF1IR*, AF*

(5) Manufacturer: Aquasant Messtechnik AG

(6) Address: Hauptstrasse 22, 4416 Bubendorf, SWITZERLAND

(7) The equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) Electrosuisse SEV, notified body No. 1258, in accordance with article 17 of Directive 2014/34/EU of the European parliament and of the council, dated 26 February 2014, certifies that this product has been found to comply with the essential health and safety requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no 16-Ex-0082.01

(9) Compliance with the essential health and safety requirements has been assured by compliance with:

EN 60079-0:12 + A11:13

EN 60079-11:12

EN 60079-26:15

EN 60079-28:15

Except in respect of those requirements listed at item 18 of the schedule.

(10) If the sign «X» is placed after the certificate number, it indicates that the product is subjected to special conditions for safe use specified in the schedule to this certificate.

(11) This EU type examination certificate relates only to design and construction of the specified product. Further requirements of this directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

(12) The marking of the product shall include the following:



II 1 G Ex ia op is IIC T4 Ga

II 1/2 G Ex ia op is IIC T4 Ga/Gb

Electrosuisse
Notified Body ATEX

Martin Plüss
Product Certification



(13)

Appendix

(14)

EU-Type Examination Certificate

(15) **Description of product**

AF1IR L for safety level switch for tank trucks (filling monitoring):

The liquid probe AF1IR is determined for home, basement and underground tanks as well as cisterns and external tanks monitoring. Combined with a level switch it is impossible to overflow the tanks. The AF1IR is almost insensitive to changes in temperature, dirt, foam, condensate etc. Compared to liquid probes with passive monitoring elements it is absolutely stable and reliable. Probe available in diverse versions.

AF1SL special level switch & leak detection system

For the general monitoring of non-aggressive and noncorrosive liquids as diverse oils, fuels, kerosene and waste waters etc. Materials in contact with the medium: Cabelec® and DURAN glass.

Applications: Drain channels, clarification plants, sewage processing plants, cable shafts, pools, weighing tanks, pipelines, filling devices, leakage monitoring. Probe available in diverse versions.

AF35SL special level switch

Version with fibre optics cable.

AF21

For the monitoring of aggressive, cold and hot liquids (-190...+350°C) such as oils, acids, bases and solvents etc. Materials in contact with the medium: 1.4404 and quartz glass. Inline-sterilization possible.

Can be applied in: All liquids as solvents, chemicals, acids, bases and petroleum products.

AF23 P1

For monitoring of diverse conductible chemicals. Stain-resistant, high durability against external influences (acids).

Materials in contact with the medium: Teflon PTFE, distance tube 1.4435; FEP coating.

AF26

For the monitoring of liquids in glass bottles via a fused in optical nose for aqueous or alcoholic solvents, diverse oils, acids, bases and solvents etc. Materials in contact with the medium: Quartz glass. For use in laboratories, mini plants and for sterile filling.

AF23 / AF 23 U748

Probe stainless steel 1.4404. Inline-sterilization possible. Durable in petroleum, cooking oils, petrol, kerosene, acids, bases and solvents etc. Can be applied in: petro chemistry, water supply facility, sewage processing plant, storage tanks, pool, tankers etc. Particularly suitable as safety level switch and leak warning protection.

AF33

Mechanical structure as AF23. Useable in: exposed zones as with petrol and solvents tanks. No electric connections. Signal transmission by fibre optics cable. Useable without lightning protection.

AF33 P1

For monitoring of diverse conductible chemicals. Stain-resistant, high durability against external influences (acids). Material in contact with the medium: Teflon PTFE, distance tube 1.4435; FEP coating. No electric connections. Signal transmission by fibre optics cable. Useable without lightning protection.

AF42

Execution in 1.4404. Self-monitoring in submerged status (FSL). Minimal-level monitoring. Useable in: Insulator oil of transformers, dry-running protection of large pumps, lubricant monitoring for the protection of machines and plants. Ensure the fuel and propellants supply.

Functional principle of the Aquasant liquid probes:

The optically active part of the liquid probe is designed as a 90° glass cone. According to the refraction law the infrared light beam striking on the boundary surface (glass / medium) will be totally reflected (Totalreflexion). This is given by the geometry of the probe's cone, as long as a gaseous medium surrounds the probe's cone. By means of the twice total reflection the infrared light beam will be conducted to the receiver (Empfänger). This signal will be interpreted as low-level indication.

When the probe's cone immerses into the liquid the infrared light beam will be broken on the boundary surface (glass / medium) and shines into the liquid. The infrared light beam will not reach the receiver. This signal will be interpreted as high-level indication.

Ratings:

Liquid detectors AF*

Sensor circuit

with type of protection intrinsic safety Ex ia IIC
only for connection to a certified intrinsically safe circuit.

Maximum values:

$U_i \leq 7.2 \text{ V}$

$I_i \leq 96.0 \text{ mA}$

$P_i \leq 692 \text{ mW}$

$C_i = 0$

$L_i = 0$

Liquid detectors AF1IR*

Sensor circuit A-C

with type of protection intrinsic safety Ex ia IIC
only for connection to a certified intrinsically safe circuit.

Maximum values:

$U_i \leq 24.0 \text{ V}$

$P_i \leq 25 \text{ mW}$

$C_i = 0$

$L_i = 0$

Sensor circuit B-C

with type of protection intrinsic safety Ex ia IIC
only for connection to a certified intrinsically safe circuit.

Maximum values:

$U_i \leq 7.2 \text{ V}$

$I_i \leq 90 \text{ mA}$

$C_i = 0$

$L_i = 0$

Classification of installation and use: stationary
Ingress protection: IP64
Rated ambient temperature range (°C): -30 °C ...+70 °C

(16) **Report number** 16-Ex-0082.01

(17) **Specific conditions of use**

- The AF***Z***** Liquid detector with zirconium housing must be installed protected against impact and friction.
- For protection level Ga the AF*****BV****, AF*****AKK**** or AF*****AKS**** Liquid detector with aluminium head must be installed protected against impact and friction.
- The AF***P1*****; AF*****S**** AF*****BV**** Liquid detector with housings consisting of Teflon, Polyamide or Polyester the electrostatic charge must be prevented. Warning of potential electrostatic charging hazard see instructions.

(18) **Essential health and safety requirements**

In addition to the essential health and safety requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject
None	

(19) **Drawings and Documents**

See test report "Manufacturer's Documents"

